



DNVFRS - CONSTRUCTION SITE REQUIREMENTS

- Please ensure that your Construction Fire Safety Plan (*CFSP*) and protection of adjacent building requirements (if applicable) is being followed at all times. If a crane is present on site, it must be registered with THARRP and comply with the associated process.
- Be advised that random site visits will be conducted by the Fire Department.
- Any fire hydrants located on-site must remain clear and accessible for Fire Department use. A minimum of 1 metre of clearance is required around each hydrant, and hydrants must remain outside of any construction fencing.
- Ensure that appropriate access points are always maintained for Fire, BC Ambulance, and other first responders (*especially after hours*).
- Site address numbers must be clearly visible and of sufficient size to be easily identified from the street.
- Fire department access signs must be provided at all construction site fire access points. A construction site plan must also be included at all access points.
- At all horn stations, portable fire extinguishers must be inspected and serviced within the past 12 months.
- If a standpipe system is part of the development, it must be installed and charged progressively. Any completed storey should have an operational standpipe system and the ability to be charged through the Fire Department Connection (*FDC*).
(*Also review DNVFRS - DEVELOPMENT SITE WATER SUPPLY REQUIREMENTS*).
- The FDC must always remain accessible and should be clearly identified with appropriate signage, whether permanent or temporary.
- For additional information contact the DNVFRS Public Safety division.

RAFFI FETERS

Captain – Public Safety Division

District of North Vancouver Fire and Rescue Services

DNVFRS Public Safety Division – 604-980-7575 or firecom@dnv.org